



ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ  
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਬਾਘਾਪੁਰਾਣਾ(ਮੋਗਾ)।  
ਈ-ਮੇਲ: sdebpa@yahoo.com


**CERTIFICATE REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**

No.....208.....

Date 10-04-24

It is certified that an inspection team headed by Er. Manwinder Singh J.E ,from Sub Divisional Engineer, Water Supply & Sanitation Sub Division, Baghapurana, District Moga inspected the Punjab Convent Sen.Sec.School,Baghapurana (Moga) on 02-04-2024 and reported that the source of drinking water was safe as per lab report and sanitation facilities for the students and staff members of institution was as per norms prescribed by the Department of Water Supply & Sanitation and is being maintaining for the hygienic condition also.

The above NOC is valid for period from of 10-04-2024 to 09-04-2025

  
Sub-Divisional Engineer,  
Water Supply & Sanitation Sub-Division,  
Bagha Purana.

Signature With Seal:-

Name:-

Designation:-

Name &Adress of the Office:-

.....  
Balwinder Singh

Sub Divisional Engineer

Water Supply & Sanitation,  
Sub Division-Baghapurana


To.

Principal

Punjab Convent Sen.Sec. School,

Baghapurana(Moga)

(Name and Address of the Institution)

  
Principal  
Punjab Convent Sen Sec School  
School No 20417  
Channu Wala Road, Bagha Purana

**REGIONAL WATER TESTING LAB, MOGA**

Near BSNL exchange, water works, Moga (Ajitwal)  
rwtlmoga@gmail.com

To,

Punjab Convent Sen. Sec. School  
Channu Wala Road, Bagha Purana


No.: RWTLMOG/2425/00001 Dated : 09/04/2024

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. PCS offi-725/1233/2024 Dated: 27/03/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 02/04/2024. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Moga

D/A : Test Report



Authorized Signatory  
For, Regional Water Testing Lab  
Moga



Principal  
Punjab Convent Sen Sec School  
School No 20417  
Channu Wala Road, Bagha Purana

**REGIONAL WATER TESTING LAB, MOGA**Near BSNL exchange, water works, Moga (Ajitwal)  
rwtlmoga@gmail.com

TC-12929

**TEST REPORT**

Name & Address of Customer : <b>Punjab Convent Sen. Sec. School Channu Wala Road, Bagha Purana</b>		Customer Reference No.	No : PCS offi-725/1233/2024 Dated : <b>27/03/2024</b>			
		Sample Submitted by	<b>Devinder Singh</b>			
		Date of Sample Receipt	<b>02/04/2024</b>			
		Analysis Starting Date	<b>04/04/2024</b>			
		Analysis completion Date	<b>05/04/2024</b>			
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>				
ULR No.:	<b>TC129292400000056F</b>	Sample Type :	<b>Water</b>			
Test Report No.:	<b>RWTLMOG/2425/00001</b>	Date of Issue :	<b>09/04/2024</b>			
Registration no.:	<b>RWTLMOG/REG2425/00001</b>	Condition of Sample :	<b>Sealed</b>			
Collection Point:	<b>Treatment Plant (RO/CWPP/ARP/HH Purifier)</b>	Quantity/Type of Bottle:	<b>1000 ml / Plastic Bottles</b>			
Scheme/Source:	<b>Not Mentioned(Not Mentioned)</b>	Location/Depth :	<b>School RO Water ( Punjab Convent Sen. Sec. School Channu Wala Road, Baghapurana) / NA</b>			
Village :	<b>Not Mentioned</b>	Habitation :	<b>Not Mentioned</b>			
Block:	<b>Not Mentioned</b>	District :	<b>Moga</b>			
Latitude :	<b>Not Mentioned</b>	Longitude:	<b>Not Mentioned</b>			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.81@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	110	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	32	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	72	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	16	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	8	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method


  
Principal

**Punjab Convent Sen Sec School  
School No 20417  
Channu Wala Road, Bagha Purana**

**REGIONAL WATER TESTING LAB, MOGA**

Near BSNL exchange, water works, Moga (Ajitwal)

rwtlmoga@gmail.com



TC-12929

11	Chloride	36	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---

Note: Detection Limit(Turbidity:0.5, )

This Report is issued under the following terms &amp; Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Ashish Kumar  
Sr. Chemist  
Authorized Signatory  
For,Regional Water Testing Lab  
Moga

----- End of the Test Report -----

Principal  
Punjab Convent Sen Sec School  
School No 20417  
Channu Wala Road, Bagha Purana